

Monroe, Pamela

From: Nelson, Kurt I <kurt.nelson@eversource.com>
Sent: Friday, March 13, 2020 3:26 PM
To: Price, David
Cc: Comstock, Gregg; Monroe, Pamela; Dumville, Adam; Champy, Dena M; Sarah Allen; Sperry, Joseph R; Cardin, Matthew R; Barthel, Philip
Subject: Wetlands Condition 55 - submarine cable as-built status

EXTERNAL: Do not open attachments or click on links unless you recognize and trust the sender.

Hi Dave,

After review of the supplied submarine cable as-built information it has been determined that further work is required to achieve full cable protection near the eastern shore landing in the vicinity of the salt marsh restoration area and therefore construction is not yet complete.

We apologize for the previous notice indicating that construction had been completed. Eversource is reviewing options to complete this work with our contractor and will coordinate with DES as required to complete the work. I will give you a call to discuss.

Thanks.

Kurt I. Nelson
Sr. Land Use Licensing & Permitting Specialist



13 Legends Drive
Hooksett, NH 03106
(603) 714-3031 (cell) (603) 634-3256 (office)
Kurt.nelson@eversource.com

From: Price, David <David.Price@des.nh.gov>
Sent: Monday, March 9, 2020 10:20 AM
To: Nelson, Kurt I <kurt.nelson@eversource.com>
Cc: Comstock, Gregg <Gregg.Comstock@des.nh.gov>; Monroe, Pamela <Pamela.Monroe@sec.nh.gov>; Dumville, Adam <adam.dumville@mclane.com>; Champy, Dena M <dena.champy@eversource.com>; Sarah Allen <sallen@normandeau.com>; Sperry, Joseph R <joseph.sperry@eversource.com>; Cardin, Matthew R <matthew.cardin@eversource.com>; Barthel, Philip <philip.barthel@eversource.com>
Subject: RE: SRP Wetlands Condition 55- request for extension

EVERSOURCE IT NOTICE – EXTERNAL EMAIL SENDER ** Don't be quick to click! ******

Do not click on links or attachments if sender is unknown or if the email is unexpected from someone you know, and

never provide a user ID or password. Report suspicious emails by selecting 'Report Phish' or forwarding to SPAMFEEDBACK@EVERSOURCE.COM for analysis by our cyber security team.

Hi Kurt,

Thank you for the information. DES will allow the deadline to be extended to March 13, 2020 to submit the as-built submarine cable drawings in accordance with Wetland Permit Condition #55.

David Price

Wetlands Bureau, Land Resources Management
Water Division, NH Department of Environmental Services
P.O. Box 95
Concord, NH 03302-0095
Phone: (603) 559-1514
Email: david.price@des.nh.gov



Follow us on Twitter!



Like us on Facebook!

We greatly appreciate your feedback, please take a moment to fill out our [NHDES-LRM customer satisfaction survey](#)

From: Nelson, Kurt I <kurt.nelson@eversource.com>

Sent: Monday, March 9, 2020 9:57 AM

To: Price, David <David.Price@des.nh.gov>

Cc: Dumville, Adam <adam.dumville@mclane.com>; Champy, Dena M <dena.champy@eversource.com>; Sarah Allen <sallen@normandeau.com>; Sperry, Joseph R <joseph.sperry@eversource.com>; Cardin, Matthew R <matthew.cardin@eversource.com>; Barthel, Philip <philip.barthel@eversource.com>

Subject: SRP Wetlands Condition 55- request for extension

EXTERNAL: Do not open attachments or click on links unless you recognize and trust the sender.

Hi Dave,

Eversource was planning on submitting the as-built submarine cable drawings today for the Seacoast Reliability Project pursuant to NHDES Wetlands Condition 55 (see below), however, upon recent review we have discovered a survey error that needs correction. Our engineering group should be receiving updated survey data from our cable contractor and are anticipating having the plans finalized by the end of the week.

With your permission we request that the as-built submittal deadline be extended to March 13, 2020.

Wetlands Permit Condition 55:

Cable Depths and As-Builts: To the maximum extent practicable, the maximum jet plow and hand-jetting trench depths shall be in accordance with the depths defined in the design drawings submitted July 27, 2018, and in conjunction with Document 1 of the supplemental information filed with the Site Evaluation Committee on June 30, 2017 titled "Revised Modeling Sediment Dispersion from Cable Burial for Seacoast Reliability Project, Upper Little Bay, New Hampshire, June 2017". As-Builts (including plan and profiles) showing the actual depths and locations of the cable as well as the location of concrete mattresses shall be provided to NH DES within sixty (60 days) following completion of cable installation. If directed by NHDES, as-built information for the portion of cables installed by jet plow (not hand-jetting) shall be provided to NHDES after each individual cable installation and prior to the next cable installation.

Thank you.

Kurt I. Nelson
Sr. Land Use Licensing & Permitting Specialist



13 Legends Drive
Hooksett, NH 03106
(603) 714-3031 (cell) (603) 634-3256 (office)
Kurt.nelson@eversource.com

This electronic message contains information from Eversource Energy or its affiliates that may be confidential, proprietary or otherwise protected from disclosure. The information is intended to be used solely by the recipient(s) named. Any views or opinions expressed in this message are not necessarily those of Eversource Energy or its affiliates. Any disclosure, copying or distribution of this message or the taking of any action based on its contents, other than by the intended recipient for its intended purpose, is strictly prohibited. If you have received this e-mail in error, please notify the sender immediately and delete it from your system. Email transmission cannot be guaranteed to be error-free or secure or free from viruses, and Eversource Energy disclaims all liability for any resulting damage, errors, or omissions.

This electronic message contains information from Eversource Energy or its affiliates that may be confidential, proprietary or otherwise protected from disclosure. The information is intended to be used solely by the recipient(s) named. Any views or opinions expressed in this message are not necessarily those of Eversource Energy or its affiliates. Any disclosure, copying or distribution of this message or the taking of any action based on its contents, other than by the intended recipient for its intended purpose, is strictly prohibited. If you have received this e-mail in error, please notify the sender immediately and delete it from your system. Email transmission cannot be guaranteed to be error-free or secure or free from viruses, and Eversource Energy disclaims all liability for any resulting damage, errors, or omissions.