

September 29, 2016

**Via Electronic Mail & Hand Delivery**

Pamela Monroe, Administrator  
New Hampshire Site Evaluation Committee  
21 South Fruit Street, Suite 10  
Concord, NH 03301-2429

**Re: Site Evaluation Committee Docket No. 2015-06  
Joint Application of Northern Pass Transmission LLC and Public Service Company  
of New Hampshire d/b/a Eversource Energy (the “Applicants”) for a Certificate of  
Site and Facility – Revised Photosimulations**

Dear Ms. Monroe:

Enclosed for filing in the above-captioned docket, please find one electronic copy and one hard copy of certain revised photosimulations and their accompanying pages included in the Visual Impact Assessment (“VIA”). The enclosed documents replace Attachments 8 and 9 of the February 26, 2016 filing, namely, the Private Property Photosimulations pages 1-85, and Photosimulations of Leaf-off Conditions pages 1-206.

The photosimulations submitted to the SEC with the Application on October 19, 2015, and on February 26, 2016, for the high voltage direct current (“HVDC”) portion of the Project were based on design specifications from early 2015. When the change was made from the 300 +/- kV design to a 320 +/- kV design, however, a slight upward shift was made in the cross-arm locations on the structures, on the order of three to five feet, but the structure heights did not change. The cross-arm location change was not reflected in the design structure library that was provided to the Project’s visual impact expert.

The enclosed photosimulations reflect the minor modifications to the cross-arm location on the affected structures and of the associated conductor height and accurately represent the proposed Project design. The photosimulations for the 345 kV HVAC segment were not affected.


Terrence DeWan has confirmed that the changes do not alter the VIA, and do not change his ultimate conclusions with respect to the Project.

The Applicants will upload a copy of the revised photosimulations to the ShareFile site and will mail electronic copies to each intervenor group and Counsel for the Public.

NPT – Revised Photosimulations  
September 29, 2016  
Page 2

Please contact me directly should you have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "Thomas B. Getz". The signature is fluid and cursive, with a large loop at the beginning and a long, sweeping tail.

Thomas B. Getz

TBG:amd

cc: SEC Distribution List

Enclosures