

From: Rebecca Lawrence <ralbox613@gmail.com>
Sent: Thursday, February 27, 2020 9:21 AM
To: Monroe, Pamela <Pamela.Monroe@sec.nh.gov>
Subject: Re: Chinook Solar--SEC Docket No. 2019-02

EXTERNAL: Do not open attachments or click on links unless you recognize and trust the sender.

Hello Ms. Monroe,

Please be advised that as a thirty plus year resident of Fitzwilliam, NH I am opposed to the Chinook Solar Farm proposed by Nextera.

In particular, I am deeply concerned regarding the request for a waiver as noted:

4. Chinook respectfully requests a waiver from the decommissioning requirement that all underground infrastructure at depths less than four feet below grade be removed from the site. Chinook proposes that it only be required as part of the decommissioning plan to remove material and equipment that is three feet or less below finished grade. Under the National Electric Code electric cables are required to be buried a minimum of three feet below grade when the cable is above a certain voltage class.

2

Since AC collection cables for Chinook will be installed at a minimum depth of three feet in accordance with the electric code, and their subsequent removal would cause ground disturbance, Chinook requests that only cables installed at three feet or less in depth, as well as other equipment that is located underground at depths of three feet or less, be removed during decommissioning.

Please advise me of what materials they plan to install at a depth of below 3 feet and the subsequent impact on the environment of not removing said materials.

Thank you.
Sincerely,
Rebecca Lawrence